

Notice of Determination

Appendix D

To:

[X] Office of Planning and Research
U.S. Mail: Street Address:
P.O. Box 3044 1400 Tenth St., Rm 113
Sacramento, CA 95812-3044 Sacramento, CA 95814

[X] County Clerk
County of: Sacramento
Address: 600 8th Street
Sacramento, CA 95814

From:

Public Agency: Sacramento Municipal Utility District
Address: 6201 S Street, MS H203
Sacramento, CA 95817
Contact: Rob Ferrera
Phone: (916) 732-6676

Lead Agency (if different from above):
Address:
Contact:
Phone:

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 2010062069

Project Title: Cordova Hills

Project Applicant: Sacramento Municipal Utility District

Project Location (include county): S Street between 59th and 65th Streets in Sacramento, CA

Project Description:

SMUD is proposing to design, construct and operate two 69/12 kilovolt (kV) substations and associated infrastructure to serve the Cordova Hills Development. While the 2012 FEIR described and analyzed three substations in total, SMUD is currently only proposing to develop the first two. There are existing 12kV overhead electrical distribution lines along Grant Line Road and internal to the Cordova Hills Development project boundary. In order to supply power to the two substations, SMUD would construct overhead 69kV sub-transmission lines connecting each substation to the existing Cordova Bulk Transmission Substation, located at the northwest limit of the Project on Douglas Road.

This is to advise that the Sacramento Municipal Utility District has approved the above (X) Lead Agency or ( ) Responsible Agency)

described project on April 23, 2019 and has made the following determinations regarding the above described project.

- 1. The project [ ] will [X] will not] have a significant effect on the environment.
2. [X] An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.
[ ] A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures [X] were [ ] were not] made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan [X] was [ ] was not] adopted for this project.
5. A statement of Overriding Considerations [X] was [ ] was not] adopted for this project.
6. Findings [X] were [ ] were not] made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the negative Declaration, is available to the General Public at:

SMUD, 6201 S Street, MS B203, Sacramento, CA 95817-1899

Signature (Public Agency): [Signature] Title: Environmental Specialist II

Date: April 23, 2019 Date Received for filing at OPR: Governor's Office of Planning & Research

APR 26 2019