

Notice of Intention to Adopt a Mitigated Negative Declaration / Notice of Availability

Notice is Hereby Given: The City of Parlier (City) is the Lead Agency on the below-described project and has prepared a Mitigated Negative Declaration on the proposed TCP Removal Treatment System Project (Project), which includes improvements to the existing water system in the City. The complete Project description, location and the potential environmental effects are contained in the Mitigated Negative Declaration (MND). The MND has concluded that no significant environmental impacts will occur as a result of the Project.

Project Title: Mitigated Negative Declaration for the Parlier 1, 2, 3 – TCP Removal Treatment System

Project Location: The project is located in the City of Parlier in three general areas: Location 1: This component extends from east of the intersection of South Whitner Avenue and Young Avenue south to Tuolumne Street, then west along Tuolumne Street, and south along South Milton Avenue, including adjacent to the Milton Lift Station, to the intersection with East Manning Avenue. Location 2: This component is on the south side of Industrial Drive, 0.1 miles west of South Mendocino Avenue. Location 3: This component is on the northeast corner of East Parlier Avenue and South Zediker Avenue.

Project Description: The City of Parlier intends to construct a water treatment system designed to remove 1, 2, 3 – Trichloropropane (TCP) from the water system due to levels above State Water Board maximum permitted levels. There are three components to the Project: Component 1: Component 1 will centralize TCP treatment for Well #2A and Well #4A, next to the existing Milton Lift Station site. The project will include approximately 340 linear feet (LF) of 10” pipeline between Well #2A and the proposed centralized treatment site, and approximately 3,370 LF of 10” pipeline between Well #4A and the proposed centralized treatment site. The new centralized treatment plant will include a six “train” TCP treatment system capable of handling the combined flow of Well #2A and Well #4A. Each treatment “train” consists of an individual 12 foot granular activated carbon (GAC) vessel and related equipment. Component 2: The second component includes the construction of a new TCP treatment system at Well #9A. Component 3: The last component includes the rehabilitation of the existing Well #5 to convert it from a standby source into an active water source. This well will replace water from other wells that are out of compliance.

Document Availability and Public Review Timeline: Due to the time limits mandated by State law, your response to the Mitigated Negative Declaration must be sent at the earliest possible date *but not later than 30 days* after receipt of this notice. The review period for the Mitigated Negative Declaration will be from March 28, 2019 to April 29, 2019. Copies of the Mitigated Negative Declaration can be reviewed at the City of Parlier, 1100 E. Parlier Ave., Parlier, CA 93648.

Please send your comments to Bertha Augustine at the address shown above or by email: bertha@parlier.ca.us.

City Council Consideration: The Parlier City Council intends to conduct a public hearing and consider the Mitigated Negative Declaration for adoption on:

Date:	Thursday, May 2, 2019
Time:	On or after 6:30 p.m.
Location:	City Council Chambers 1100 E. Parlier Ave. Parlier, CA 93648