



State Water Resources Control Board

NOTICE OF INTENT TO ADOPT A MITIGATED NEGATIVE DECLARATION

(Pursuan) to CEQA Section 21092 and CEQA Guidelines Section 15072)

PROJECT TITLE: California Water Service Company (Cal Water) - Dominguez (DOM) 300-01 New Well

Project (Project)

WATER SYSTEM#: 1910033

APPLICANT: State Water Resources Control Board

PROJECT LOCATION: 958 West Walnut Street (33.8752088, -118.2392430), Compton, Los Angeles County

PROJECT DESCRIPTION: Cal Water proposes to improve water service reliability by construction of a new water supply well to an estimated depth of 800 feet and capacity of 2.16 to 2.88 million gallons per day. The Project includes drilling, construction and testing of the new well. A catch basin and connection to an existing storm drain will be constructed to discharge water during the well development process. Prior to drilling, a temporary noise wall will be erected along the eastern property border to shield Fire Station No. 4 from construction noise. A slump stone building will be constructed to house the electrical and treatment facilities if needed, and will contain aeration equipment, ion exchange vessels, booster pumps, and chemical injection facilities. Fencing, a security system, paving, and landscaping will be included in site development.

COMMENT PERIOD:

STARTING DATE: April 26, 2019 ENDING DATE: May 26, 2019

NOTICE IS HEREBY GIVEN that the State Water Board intends to adopt a California Environmental Quality Act (CEQA) Mitigated Negative Declaration for the Project in accordance with CEQA Guidelines.

ADDRESS WHERE COPIES OF THE PROPOSED MITIGATED NEGATIVE DECLARATION, INITIAL STUDY AND REFERENCE ARE AVAILABLE FOR REVIEW:

State Water Resources Control Board Angeles District Office 500 North Central Avenue, Suite 500 Glendale, CA 91203

The Project site is not present on any of the lists enumerated under section 65962.5 of the government code.