

Notice of	Exe	m	pti	on
-----------	-----	---	-----	----

To: County Clerk

From: San Diego County Water Authority

County Of San Diego

4677 Overland Avenue

1600 Pacific Highway, Room 260 MS A-33

San Diego, CA 92123-1233

San Diego, CA 92101

State Clearinghouse

Email: state.clearinghouse@opr.ca.gov
Project Title: Pipeline 5 Rejection Tower Rehabilitation (Q0332)
Project Location - Specific: The project is located in the unincorporated area near the Twin Oaks
Valley Water Treatment Plant at 3566 North Twin Oaks Valley Road, San Marcos, CA 92069.
Project Location - City: unincorporated Project Location - County: San Diego
Description of Nature, Purpose, and Beneficiaries of Project: The project consists of the
rehabilitation of an existing aqueduct appurtenant structure. The tower is a 61-foot-tall 74-inch diameter
vent surrounded by a 67-foot-tall 122-inch diameter containment pipe; both constructed of cement
mortar lined and coated welded steel. A condition assessment revealed delaminated and spalled
cement mortar coating on the steel vent and coating debris at the bottom of the containment pipe.
This project is to remove the remaining delaminated cement mortar coating from the vent during an
aqueduct shutdown to prevent the coating debris from damaging downstream aqueduct facilities.
Name of Public Agency Approving Project: San Diego County Water Authority Name of Person or Agency Carrying Out Project: San Diego County Water Authority
Exempt Status: ☐ Ministerial (Sec. 21080(b)(1); 15268); ☐ Declared Emergency (Sec. 21080(b)(3); 15269(a)); ☐ Emergency Project (Sec. 21080(b)(4); 15269(b)(c)); ☐ Categorical Exemption. State type and section number: Class 1 Existing Facilities (Sec. 15301) ☐ Statutory Exemption. State code number:
Reasons why project is exempt: The project is the maintenance of existing public water facilities,
within the existing structure, with no expansion of use.
Lead Agency Mark Tegio, Sr. Water Contact Person: Resources Specialist Telephone: 858-522-6753
Signature: Willy Lille Date: May 24, 2019 Title: Director of Water Resources Kelley Gage
L:\WRIDeptOnly/3221-ENVIRON410 CEQA\Categorical Examptions\000332 Rejection Tower Rehabilitation\000322 Rejection MAY 21 2010

STATECLEARINGHOUSE